

GENERATOR SET SPECIFICATIONS

Minimum Rating	20 kVA
Maximum Rating	22 kVA
Emissions/Fuel Strategy	R96/EUIIIa Equivalent
Voltage	200 to 400 Volts
Frequency	50 Hz
Duty Cycle	Standby, Prime

C2.2 | DE22E3 STANDARD EQUIPMENT

ENGINE

- Electrical system, 12 VDC

EXHAUST SYSTEM

- Dry exhaust manifolds

FUEL SYSTEM

- Actuator with electronic governor

C2.2 | DE22E3 OPTIONAL EQUIPMENT

AIR INLET

- Air inlet adapters

COOLING SYSTEM

- Inlet/outlet connections

EXHAUST

- Flexible fitting